National Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for August 2017

| Issue Date: 28/04/20 | Issue Time: 1300 Hrs | | | Revision No. 0 | | | | |
|---|---|--|-----------------------|---|--|---|---|----------|
| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
| 1st August 2017 to 31st August 2017 | 00 - 24 | 7598 | 300 | 7298 | 4193 | 3105 | | |
| Limiting Constraints (any one or combination thereof) | i. (n-1) of 765/400kV ICT at Tiruvalem. ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit iii. (n-1) contingency of one circuit of 400 kV Mettur-Karamadai will lead to overloading of the other circuit iv. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit v. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit vi. Low Voltage in Kerala (S3) | | | | | | | |
| Note-1 | S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa (SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala | | | | | | | |
| Note-2 | (n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Sheme (SPS) | | | | | | | |

National Load Despatch Centre, New Delhi Transfer Capability for Import of S3 for August 2017

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|--|---|--|-----------------------|---|--|---|---|----------|
| 1st August 2017 to 31st August 2017 | 00-24 | 3062 | 73 | 2989 | 2297 | 692 | | |
| Limiting Constraint (any one or | i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit ii. Low Voltage in Kerala (S3) | | | | | | | |
| Note-1 | S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala | | | | | | | |
| Note-2 | (n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System | | | | | | | |

National Load Despatch Centre Transfer Capability between S1- (S2&S3) for August 2017 Transfer Capability for Import of S3 for August 2017

|] | Revision No | Date of Revision | Period of Revision | Reason for Revision | Corridor |
|---|----------------|---------------------|-----------------------------|----------------------------|----------|
| | 0 | 28-04-2017 | 01-08-2017 to 31-08-2017 | Revision-0 | - |