Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for February 2019

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st Feb 2019 to 28th Feb 2019	00 - 24	8600	470	8130	3719	4411			
Limiting Constraints (any one or combination thereof)	i. (n-1) of one 765/400kV ICT at Tiruvalum will lead to overloading of the second ICT.								
	ii. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS								
	iii. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit								
	iv. Low Voltage in Kerala (S3)								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)								

Natioanl Load Despatch Centre, New Delhi Transfer Capability for Import of S3 for February 2019

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Feb 2019 to	00-07	3010	90	2920	2581	339		
2th Feb 2019	07-24	2210		2120		0		
3rd Feb 2019	00-07	3010	90	2920	2581	339		
	07-24	2210	90	2120	2581	0		
4th Feb 2019	00-24	3010	90	2920	2581	339		
5th Feb 2019 to 9th Feb 2019	00-24	3010	90	2920	2581	339		
10th Feb 2019	00-09	3010	90	2920	2581	339		Revised due to shutdown of 400 kV Udumulpet-Palakkad Ckt-2
	09-24	2510		2420		0	-500	
11th Feb 2019 to 28th Feb 2019	00-24	3010	90	2920	2581	339		
Limiting Constraint (any one or combination thereof)	i. Low Voltage in Kerala (S3) ii. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit *							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre Transfer Capability between S1- (S2&S3) for February 2019 Transfer Capability for Import of S3 for February 2019

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
1	30-01-19	01-02-2019 to 28-02-2019	(1) Revised to changes in Network Topology. (2)STOA margins revised due to chnge in LGBR given in OCC	S1- (S2&S3) and S3
		01-02-2019 to 04-02-2019	Revised due to shutdown of 400kV Tirunelvelli-Trivandrum-1 & 230kV Tirunelvelli-Edamon-1 on 1st & 2nd, and 400kV Tirunelvelli-Trivandrum-2 & 230kV Tirunelvelli-Edamon-2 on 3rd & 4th	\$3
2	03-02-19	04-02-2019	Revised due to completion of planned works and not availing 400kV Tirunelvelli-Trivandrum-2 & 230kV Tirunelvelli-Edamon-2 on 3rd & 4th	\$3
3	08-02-19	10-02-2019	Revised due to shutdown of 400 kV Udumulpet-Palakkad Ckt-2 (Limiting Constraint:- Tripping of other ckt of 400 KV Udumalpet - Palakkad D/C will lead to overloading of ICTs at Udumalpet)	\$3