

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for February 2022**

Issue Date: 16/02/2022

Issue Time: 1000 Hrs

Revision No. 4

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2022 to 12th February 2022	00 - 24	8200	450	7750	3615	4135		
13th February 2022	00 - 10	8200	450	7750	3615	4135		
	10 - 24	7700	450	7250	3615	3635	-500	
14th February 2022 to 28th February 2022	00 - 24	8200	450	7750	3615	4135		
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	ii. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli stage2							
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**Natioanl Load Despatch Centre, New Delhi**  
**Import Capability of S3 for February 2022**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2022 to 5th February 2022	00-24	3150	90	3060	2800	260	-150	
6th February 2022 to 17th February 2022	00-24	3300	90	3210	2800	410		
18th February 2022	00-08	3300	90	3210	2800	410		
	08 - 24	3000	90	2910	2800	110	-300	Revision - 04 : Due to the shutdown of 400kV/220kV Madakkathara ICT-3
19th February 2022 to 28th February 2022	00-24	3300	90	3210	2800	410		
	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
Limiting Constraint (any one or	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**National Load Despatch Centre**  
**Transfer Capability between S1- (S2&S3) for February 2022**  
**Import Capability of S3 for February 2022**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Change in quantum w.r.t last revision (MW)	Corridor
0	26-10-2021	01-02-2022 to 28-02-2022	Revision-0		-
1	29-01-2022	01-02-2022 to 28-02-2022	1. Pole-4 of Raigarh-Pugalur commissioning 2.ISGS Outages approved in 186th OCC meeting	400	S1-(S2&S3)
2	30-01-2022	01-02-2022 to 05-02-2022	Revision - 02 : Due to extension of 400kV Tirunelveli-Cochin-D/C shutdown	-150	Import of S3
3	11-02-2022	13-02-2022	Revision - 3 : Due to shutdown of 400kV/230kV Trichy ICT-2	-500	S1-(S2&S3)
4	16-02-2022	18-02-2022	Revision - 04 : Due to the shutdown of 400kV/220kV Madakkathara ICT-3	-300	Import of S3