## Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for February 2023

Issue Date: 26/10/2022 Issue Time: 1800 Hrs Revision No. 0

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) *	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st February 2023 to 28th February2023	00 - 06 and 18 -24Hrs	8550	450	8100	3733	4367			
	06 - 18 Hrs	8550	450	8100	3913	4187			
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT								
	ii. N-1 violation 2x315 MVA ICTs at 400/230kV Tiruvallam SS								
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP iv. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

<sup>\* 50%</sup> of Wind export LTA Considered for STOA margin

<sup>\*</sup>Solar export LTA considered in the solar period

## Natioanl Load Despatch Centre, New Delhi Import Capability of S3 for February 2023

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2023 to 28th February 2023	00-24	3500	90	3410	2812	598		
Limiting Constraint	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT							
(any one or	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin ss will lead to over-loading of the Other ICT							
combination thereof)	iii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

## National Load Despatch Centre Transfer Capability between S1- (S2&S3) for February 2023 Import Capability of S3 for February 2023

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-10-2022	01-02-2023 to 28-02-2023	Revision-0	-