

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for January 2021

Issue Date: 03/01/2020

Issue Time: 1100 Hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2021 to 31st January 2021	00 - 24	7750	450	7300	3522	3778		
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to Low Voltage at Palakkad/Trichur & (n-1) contingency of one circuit of 400 kV Tirunelveli-Cochin will lead to Low Voltage at Cochin//Trichur.							
	ii. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS							
	iii. Low Voltage in Kerala (S3)							
	iv. N-1 violation of 400/230kV Thiruvallam ICT							
	v. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Trichy ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

Natioanal Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for January 2021

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2021 to 3rd January 2021	00-24	3300	90	3210	2757	453		
4th January 2021	00-10	3300	90	3210	2757	453		
4th January 2021	10-24	3100	90	3010	2757	253	-200	400 kV Tirunelveli-Trivendrum-2 S/D
5th January 2021 to 31st January 2021	00-24	3300	90	3210	2757	453		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to Low Voltage at Palakkad/Trichur							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
	iii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
	iv. (n-1) contingency of one circuit of 400 kV Tirunelveli-Cochin will lead to Low Voltage at Cochin/Trichur.							
	v. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for January 2021
Transfer Capability for Import of S3 for January 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-09-2020	01-01-2021 to 31-01-2021	Revision-0	-
1	03-01-2021	04-01-2021	400 kV Tirunelveli-Trivendrum-2 S/D	s3