

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for June 2022**

Issue Date: 01/06/2022

Issue Time: 1400 Hrs

Revision No. 4

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2022	00 - 06 Hrs	8200	450	7750	3485	4265	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-08 Hrs	8200	450	7750	3715	4035		
	08-18 Hrs	7450	450	7000	3715	3285		
	18-24 Hrs	7450	450	7000	3485	3515		
2nd June 2022 to 3rd June 2022	00 - 06 & 18-24 Hrs	7450	450	7000	3485	3515	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-18 Hrs	7450	450	7000	3715	3285		
4th June 2022 to 14th June 2022	00 - 06 & 18-24 Hrs	8200	450	7750	3485	4265	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-18 Hrs	8200	450	7750	3715	4035		
15th June 2022 to 17th June 2022	00 - 06 & 18-24 Hrs	8200	450	7750	3593	4157	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-18 Hrs	8200	450	7750	3823	3927		
18th June 2022 to 28th June 2022	00 - 06 & 18-24 Hrs	8200	450	7750	3653	4097	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-18 Hrs	8200	450	7750	3883	3867		
29th June 2022 to 30th June 2022	00 - 06 & 18-24 Hrs	8200	450	7750	4025	3725	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-18 Hrs	8200	450	7750	4255	3495		
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	ii. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2							
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**Natioanl Load Despatch Centre, New Delhi  
Import Capability of S3 for June2022**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2022 to 2nd June 2022	00-24	3300	90	3210	2683	527		
3rd June 2022	00-09	3300	90	3210	2683	527		
	09-24	3100	90	3010	2683	327	-200	Due to Shutdown of 400KV/220KV KOCHI-ICT-2
4th June 2022 to 14th June 2022	00-24	3300	90	3210	2683	527		
15th June 2022 to 17th June 2022	00-24	3300	90	3210	2668	542		
18th June 2022 to 28th June 2022	00-24	3300	90	3210	2631	579		
29th June 2022 to 30th June 2022	00-24	3300	90	3210	2639	571		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
	iii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**National Load Despatch Centre  
Transfer Capability between S1- (S2&S3) for June 2022  
Import Capability of S3 for June2022**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor	Quantum of Revision(MW)
0	26-02-2022	01-06-2022 to 30-06-2022	Revision-0	-	
1	30-05-2022	01-06-2022 to 30-06-2022	1.Considering latest network 2.ISGS Outages approved in OCC meeting 3.50% of wind Export LTA margin released for STOA		
2	30-05-2022	01-06-2022	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3 ( From 08:00Hrs)	S1-->(S2nS3)	-750
	30-05-2022	02-06-2022 to 03-06-2022	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3	S1-->(S2nS3)	-750
3	31-05-2022	01-06-2022 to 30-06-2022	1) 150 MW MTOA operationalization from DB Power to TANGEDCO 2)50 MW MTOA operationalization from JPVL to TANGEDCO		
4	01-06-2022	03-06-2022	Rev No-4: Due to Shutdown of 400KV/220KV KOCHI-ICT-2	Import of S3	-200