

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for June 2022

Issue Date: 02/06/2022

Issue Time: 1200 Hrs

Revision No. 5

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2022	00 - 06 Hrs	8200	450	7750	3485	4265	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-08 Hrs	8200	450	7750	3715	4035		
	08-18 Hrs	7450	450	7000	3715	3285		
	18-24 Hrs	7450	450	7000	3485	3515		
2nd June 2022 to 3rd June 2022	00 - 06 & 18-24 Hrs	7450	450	7000	3485	3515	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-18 Hrs	7450	450	7000	3715	3285		
4th June 2022 to 14th June 2022	00 - 06 & 18-24 Hrs	8200	450	7750	3485	4265	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-18 Hrs	8200	450	7750	3715	4035		
15th June 2022 to 17th June 2022	00 - 06 & 18-24 Hrs	8200	450	7750	3593	4157	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-18 Hrs	8200	450	7750	3823	3927		
18th June 2022 to 28th June 2022	00 - 06 & 18-24 Hrs	8200	450	7750	3653	4097	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-18 Hrs	8200	450	7750	3883	3867		
29th June 2022 to 30th June 2022	00 - 06 & 18-24 Hrs	8200	450	7750	4025	3725	-750	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3
	06-18 Hrs	8200	450	7750	4255	3495		
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	ii. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2							
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

Natioanal Load Despatch Centre, New Delhi
Import Capability of S3 for June2022

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2022 to 2nd June 2022	00-24	3300	90	3210	2683	527		
3rd June 2022	00-09	3300	90	3210	2683	527		
	09-24	3100	90	3010	2683	327	-200	Due to Shutdown of 400KV/220KV KOCHI-ICT-2
4th June 2022	00-09	3300	90	3210	2683	527		
	09-24	3100	90	3010	2683	327	-200	Due to Shutdown of 400KV/220KV KOCHI-ICT-1
5th June 2022 to 14th June 2022	00-24	3300	90	3210	2683	527		
15th June 2022 to 17th June 2022	00-24	3300	90	3210	2668	542		
18th June 2022 to 28th June 2022	00-24	3300	90	3210	2631	579		
29th June 2022 to 30th June 2022	00-24	3300	90	3210	2639	571		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
	iii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for June 2022
Import Capability of S3 for June2022**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor	Quantum of Revision(MW)
0	26-02-2022	01-06-2022 to 30-06-2022	Revision-0	-	
1	30-05-2022	01-06-2022 to 30-06-2022	1.Considering latest network 2.ISGS Outages approved in OCC meeting 3.50% of wind Export LTA margin released for STOA		
2	30-05-2022	01-06-2022	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3 (From 08:00Hrs)	S1-->(S2nS3)	-750
	30-05-2022	02-06-2022 to 03-06-2022	Rev No-2: Due to Shutdown of HVDC Pugalur Pole-3	S1-->(S2nS3)	-750
3	31-05-2022	01-06-2022 to 30-06-2022	1) 150 MW MTOA operationalization from DB Power to TANGEDCO 2)50 MW MTOA operationalization from JPVL to TANGEDCO		
4	01-06-2022	03-06-2022	Rev No-4: Due to Shutdown of 400KV/220KV KOCHI-ICT-2	Import of S3	-200
5	02-06-2022	04-06-2022	Rev No-5: Due to Shutdown of 400KV/220KV KOCHI-ICT-1	Import of S3	-200