

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for June 2017**

Issue Date: 02/06/2017

Issue Time: 1500 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2017 to 11th June 2017	00-24	6775	400	6375	4218	2157		
11th June 2017 to 22nd June 2017					3883	2492		
23rd June 2017 to 24th June 2017					3663	2712		
25th June 2017 to 27th June 2017					3724	2651		
28th June 2017 to 30th June 2017					3633	2742		
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit							
	ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iii. (n-1) contingency of one circuit of 400 kV Mettur-Karamadai will lead to overloading of the other circuit							
	iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	v. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability for Import of S3 for June 2017**

Issue Date: 02/06/2017

Issue Time: 1500 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2017 to 2nd June 2017	00-24	2970	80	2890	2138	752		
3rd June 2017 to 7th June 2017	00 -09 & 19 - 24	2970		2590		752		
	09 - 19	2670		2890		452	-300	
8th June 2017 to 11th June 2017	00-24	2970		2890	752			
11th June 2017 to 22nd June 2017	00-24	2970		2890	2172	718		
23rd June 2017 to 24th June 2017					2303	587		
25th June 2017 to 27th June 2017					2265	625		
28th June 2017 to 30th June 2017					2287	603		
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit							
	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

**National Load Despatch Centre**  
**Transfer Capability between S1- (S2&S3) for June 2017**  
**Transfer Capability for Import of S3 for June 2017**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Corridor</b>
0	23-Feb-17	01-06-2017 to 30-06-2017	-	-
1	29-May-17	01-06-2017 to 30-06-2017	Revised considering LGBR submitted by constituents in the 131st OCCM and generator outages approved in OCCM.	S1-(S2&S3) and Import of S3
2	03-Jun-17 to 07-Jun-17	03-06-2017 to 07-06-2017	Due to 220kV Tirunelveli - Edamon DC outage	Import of S3