Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for June 2017

Revision No. 4

Issue Time: 1200 hrs

Issue Date: 06/06/2017

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2017 to 7th June 2017	00-24	6775	400	6375	4218	2157		
	00-09	6775	400	6375	4218	2157		
8th June 2017	09-18	6620	400	6220	4218	2002	-155	Due to shutdown of 400kV MTPSII-Karamadai-I line
	18-24	6775	400	6375	4218	2157		
9th June 2017 to 11th June 2017	00-24	6775	400	6375	4218	2157		
11th June 2017 to 22nd June 2017	00-24	6775	400	6375	3883	2492		
23rd June 2017 to 24th June 2017	00-24	6775	400	6375	3663	2712		
25th June 2017 to 27th June 2017	00-24	6775	400	6375	3724	2651		
28th June 2017 to 30th June 2017	00-24	6775	400	6375	3633	2742		
	i. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit							
Limiting Constraints	ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iii. (n-1) contingency of one circuit of 400 kV Mettur-Karamadai will lead to overloading of the other circuit							
combination thereof)								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

Natioanl Load Despatch Centre, New Delhi Transfer Capability for Import of S3 for June 2017

Issue Date: 06/06/2017			Issue Time: 1200 hrs			Revision No. 4		
Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2017 to 2nd June 2017	00-24	2970	80	2890	2138	752		
3rd June 2017 to 4th June 2017	00 -09 & 19 - 24	2970				752		
	09 - 19	2670		2590		452		
5th June 2017 to 7th June 2017	00 -08 & 18 - 24	2970		2890		752		
	08 - 18	2670		2590		452		
8th June 2017 to 11th June 2017	00-24	2970		2890		752		
11th June 2017 to 22nd June 2017	00-24			2890	2172	718		
23rd June 2017 to 24th June 2017		2970			2303	587		
25th June 2017 to 27th June 2017		2970			2265	625		
28th June 2017 to 30th June 2017					2287	603		
						•		
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

National Load Despatch Centre Transfer Capability between S1- (S2&S3) for June 2017 Transfer Capability for Import of S3 for June 2017

Revision	Date of	Period of	Descen for Devision	Corridor	
No	Revision	Revision	Reason for Revision		
0	23-Feb-17	01-06-2017			
		to 30-06-2017	-	-	
1 29-May		01-06-2017	Revised considering LGBR submitted by		
	29-May-17	to 30-06-2017	constituents in the 131st OCCM and	S1-(S2&S3) and Import of S3	
		10 30-00-2017	generator outages approved in OCCM.		
2 6/1/20	6/1/2017	6/1/2017	03-06-2017 to	Due to 220kV Tirunelvelli - Edamon D/C	Import of S3
	0/1/2017	07-06-2017	outage		
3 6/4/2017	6/4/2017	05-06-2017 to	Due to 220kV Tirunelvelli - Edamon D/C	Import of S3	
		07-06-2017	07-06-2017	outage timings change	Import of 53
4	6/6/2017	6/8/2017	Due to shutdown of 400kV MTPSII-Karamadai-	S1-S2nS3	
		6/6/2017 6/8/2017		l line	51-521153