Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for June 2017

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---|--|-----------------------|---|--|---|--|----------|
| 1st June 2017 to 7th June 2017 | 00-24 | 6775 | 400 | 6375 | 4218 | 2157 | | |
| | 00-09 | 6775 | 400 | 6375 | 4218 | 2157 | | |
| 8th June 2017 | 09-18 | 6620 | 400 | 6220 | 4218 | 2002 | | |
| | 18-24 | 6775 | 400 | 6375 | 4218 | 2157 | | |
| 9th June 2017 to 11th June 2017 | 00-24 | 6775 | 400 | 6375 | 4218 | 2157 | | |
| 11th June 2017 to 22nd June 2017 | 00-24 | 6775 | 400 | 6375 | 3883 | 2492 | | |
| 23rd June 2017 to 24th June 2017 | 00-24 | 6775 | 400 | 6375 | 3663 | 2712 | | |
| 25th June 2017 to 27th June 2017 | 00-24 | 6775 | 400 | 6375 | 3724 | 2651 | | |
| 28th June 2017 to 30th June 2017 | 00-24 | 6775 | 400 | 6375 | 3633 | 2742 | | |
| Limiting Constraints (any one or combination thereof) | i. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit iii. (n-1) contingency of one circuit of 400 kV Mettur-Karamadai will lead to overloading of the other circuit iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit v. Low Voltage in Kerala (S3) | | | | | | | |
| Note-1 | S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala | | | | | | | |
| Note-2 | (n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and | | | | | | | |

Issue Time: 1210 hrs

Issue Date: 18/06/2017

Revision No. 6

Natioanl Load Despatch Centre, New Delhi Transfer Capability for Import of S3 for June 2017

| Issue Date: 18/06/2017 | | Issue Time: 1210 hrs | | | Revision No. 6 | | | |
|-------------------------------------|--|--|-----------------------|---|--|---|--|---|
| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
| 1st June 2017 to 2nd June 2017 | 00-24 | 2970 | 259 | 2890 | 2138 | 752 | | |
| 3rd June 2017 to 4th June 2017 | 00 -09 & 19 - 24 | 2970 | | | | 752 | | |
| Julie 2017 | 09 - 19 | 2670 | | 2590 | | 452 | | |
| 5th June 2017 to 7th June 2017 | 00 -08 & 18 - 24 | 2970 | | 2890 | | 752 | | |
| Julie 2017 | 08 - 18 | 2670 | | 2590 | | 452 | | |
| 8th June 2017 to 9th June 2017 | 00 -08 & 18 - 24 | 2970 | | 2890 | | 752 | | |
| | 08 - 18 | 2670 | | 2590 | | 452 | | |
| 10th June 2017 to 11th June 2017 | 00-24 | 2970 | | 2890 | 2138 | 752 | | |
| 12th June 2017 to 18th June 2017 | 00-24 | 2970 | 80 | 2890 | 2172 | 718 | | |
| | 00-08 | 2970 | | 2890 | 2172 | 718 | | Revised due to shutdown of 220kV Tirunelvelli - Edamon D/C. |
| 19th June 2017 to 20th June 2017 | 08-18 | 2670 | | 2590 | | 418 | -300 | |
| | 18-24 | 2970 | | 2890 | | 718 | | |
| 21st June 2017 to 22nd June 2017 | 00-24 | 2970 | | 2890 | 2172 | 718 | | |
| 23rd June 2017 to 24th June 2017 | 00-24 | 2970 | | 2890 | 2303 | 587 | | |
| 25th June 2017 to 27th June 2017 | 00-24 | 2970 | | 2890 | 2265 | 625 | | |
| 28th June 2017 to 30th June 2017 | 00-24 | 2970 | | 2890 | 2287 | 603 | | |
| | | | | | | | | |
| Limiting Constraint (any one or | ii. Low Voltag | ge in Kerala (S | 53) | | | ading of the other circ | | 60 · K I |
| Note-1 | S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala (n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and | | | | | | | |
| Note-2 | (II-1) continge | ancy of 400/22 | to ici at Kozni | toue is not considered | i winne assessing | i i c because of the r | autai nature | or road in North Kerala and |

| Revision | Date of | Period of | Reason for Revision | | | |
|----------|-------------|---------------|--|--|--|--|
| No | Revision | Revision | Keason for Kevision | | | |
| 0 | 23-Feb-17 | 01-06-2017 | Revision-0 | | | |
| | 23-FED-17 | to 30-06-2017 | Revision-0 | | | |
| 1 | 29-May-17 | 01-06-2017 | Revision-1 | | | |
| | 29-1VIdy-17 | to 30-06-2017 | Kevision-1 | | | |
| 2 | 01-06-2017 | 03-06-2017 to | Due to 220kV Tirunelvelli - Edamon D/C | | | |
| Z | 01-00-2017 | 07-06-2017 | outage | | | |
| 3 | 04-06-2017 | 05-06-2017 to | Due to 220kV Tirunelvelli - Edamon D/C | | | |
| 5 | 04-00-2017 | 07-06-2017 | outage timings change | | | |
| 4 | 06-06-2017 | 08-06-2017 | Due to shutdown of 400kV MTPSII-Karamadai- | | | |
| 4 | 00-00-2017 | 08-00-2017 | l line | | | |
| 5 | 07-06-2017 | 08-06-2017 to | Due to 220kV Tirunelvelli - Edamon D/C | | | |
| Э | 07-06-2017 | 09-06-2017 | outage | | | |
| 6 | 18-06-2017 | 19-06-2017 to | Revised due to shutdown of 220kV | | | |
| 6 | 10-00-2017 | 20-06-2017 | Tirunelvelli - Edamon D/C | | | |

National Load Despatch Centre Transfer Capability between S1- (S2&S3) for June 2017 Transfer Capability for Import of S3 for June 2017

| Corridor |
|--------------|
| - |
| |
| Import of S3 |
| Import of S3 |
| S1-S2nS3 |
| Import of S3 |
| Import of S3 |