

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for March 2019

Issue Date: 08/03/2019

Issue Time: 1815 Hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Mar 2019 to 31st Mar 2019	00 - 24	9300	490	8810	3800	5010		
Limiting Constraints (any one or combination thereof)	i. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS							
	ii. (n-1) contingency of one circuit of 400 kV Hosur - Salem will lead to overloading of the other circuit							
	iii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	v. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for March 2019

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Mar 2019 to 9th Mar 2019	00-24	3010	90	2920	2598	322		
10th Mar 2019	00-13	3010	90	2920	2598	322	-500	Revised due to shutdown of 230kV Tirunelveli-Edamon D/C
	13-18	2510		2420		0		
	18-24	3010		2920		322		
11th Mar 2019 to 31st Mar 2019	00-24	3010	90	2920	2598	322		
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit *							
	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for March 2019
Transfer Capability for Import of S3 for March 2019

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-11-2018	01-03-2019 to 31-03-2019	Revision-0	-
1	28-02-2019	01-03-2019 to 31-03-2019	S1-(S2&S3) TTC increase due to commisioning Tumkur Dharmapuri D/C, Tumkur Cuddapah D/C. KKNP U1 and MAPS U1 outage considered	S1-(S2&S3) and S3
2	08-03-2019	10-03-2019	Revised due to shutdown of 230kV Tirunelveli-Edamon D/C	S3