

**Natioanal Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for March 2019**

Issue Date: 09/03/2019

Issue Time: 1325 Hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Mar 2019 to 31st Mar 2019	00 - 24	9300	490	8810	3800	5010		
Limiting Constraints (any one or combination thereof)	i. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS							
	ii. (n-1) contingency of one circuit of 400 kV Hosur - Salem will lead to overloading of the other circuit							
	iii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	v. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability for Import of S3 for March 2019**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Mar 2019 to 9th Mar 2019	00-24	3010	90	2920	2598	322		
10th Mar 2019	00-13	3010	90	2920	2598	322	-500	Revised due to shutdown of 230kV Tirunelveli-Edamon D/C
	13-18	2510		2420		0		
	18-24	2510		2420		0		
11th Mar 2019 to 31st Mar 2019	00-24	3010	90	2920	2598	322		
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit *							
	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

**National Load Despatch Centre**  
**Transfer Capability between S1- (S2&S3) for March 2019**  
**Transfer Capability for Import of S3 for March 2019**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Corridor</b>
0	26-11-2018	01-03-2019 to 31-03-2019	Revision-0	-
1	28-02-2019	01-03-2019 to 31-03-2019	S1-(S2&S3) TTC increase due to commisioning Tumkur Dharmapuri D/C, Tumkur Cuddapah D/C. KKNP U1 and MAPS U1 outage considered	S1-(S2&S3) and S3
2	08-03-2019	10-03-2019	Revised due to shutdown of 230kV Tirunelvelli-Edamon D/C	S3