

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for March 2020

Issue Date: 28th November 2019

Issue Time: 1700 Hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2020 to 31st March 2020	00 - 24	7300	490	6810	3609	3201		
Limiting Constraints (any one or combination thereof)	i. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS ii. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit iii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for March 2020

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2020 to 31st March 2020	00-24	3150	90	3060	2742	318		
Limiting Constraint (any one or combination thereof)	i. Contingency of 400kV Tirunelveli - Cochin 1 will lead to under voltage at 400kV Thrissur S/S							
	ii. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit *							
	iii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for March 2020
Transfer Capability for Import of S3 for March 2020

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor