

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for March 2021

Issue Date: 28th November 2020

Issue Time: 1800 Hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2021 to 31st March 2021	00 - 24	8200	450	7750	3522	4228		
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to Low Voltage at Palakkad/Trichur & (n-1) contingency of one circuit of 400 kV Tirunelveli-Cochin will lead to Low Voltage at Cochin//Trichur.							
	ii. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS							
	iii. Low Voltage in Kerala (S3)							
	iv. N-1 violation of 400/230kV Thiruvallam ICT							
	v. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Trichy ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for March 2021

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2021 to 31st March 2021	00-24	3300	90	3210	2757	453		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to Low Voltage at Palakkad/Trichur							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
	iii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
	iv. (n-1) contingency of one circuit of 400 kV Tirunelveli-Cochin will lead to Low Voltage at Cochin//Trichur.							
	v. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for March 2021
Transfer Capability for Import of S3 for March 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
--------------------	-------------------------	---------------------------	----------------------------	-----------------