## Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for March 2023

Issue Date: 22/02/2023		]	Issue Time: 20	000 Hrs	Revision No. 1				
Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) *	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st March 2023 to 31st March 2023	00 - 06 and 18 -24Hrs	8550	450	8100	3637	4463			
	06 - 18 Hrs	8550	450	8100	3600	4500			
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT								
	ii. N-1 violation 2x315 MVA ICTs at 400/230kV Tiruvallam SS								
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP iv. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala						S3 comprises Kerala		

\* 50% of Wind export LTA Considered for STOA margin \*Solar export LTA considered in the solar period

## Natioanl Load Despatch Centre, New Delhi Import Capability of S3 for March 2023

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2023 to 31st March 2023	00-24	3500	90	3410	2606	804		
Limiting Constraint (any one or combination thereof)	ii. (n-1) contir	. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin ss will lead to over-loading of the Other ICT i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT						
Note-1	S1 comprises	Andhra Prade	esh, Telangana a	nd Karnataka and Go	oa(SR); S2 compri	ses Tamil Nadu and	Pondicherry; S3	comprises Kerala

Revision	Date of	Period of	<b>Reason for Revision</b>	Corridor
No	Revision	Revision	Reason for Revision	
0	26 11 2022	01-03-2023	Revision-0	
	26-11-2022	to 31-03-2023	Revision-0	-
1		01-03-2023 to 31-03-2023	1.Updated LGBR	
	22-02-2023		2.ISGS Unit outages as approved in 199th OCC	
			meeting	

## National Load Despatch Centre Transfer Capability between S1- (S2&S3) for March 2023 Import Capability of S3 for March 2023