

National Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for March 2025

Issue Date: 26/03/2024

Issue Time: 1800 Hrs

Revision No. 0

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA S1- (S2&S3) (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st to 31st Mar 2025	00 -24Hrs	1-96	10500	450	10050	5574	4476		
Limiting Constraints (any one or combination thereof)	i. Tripping of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Arasur SS								
	ii. N-1 violation 2x315 MVA ICTs at 400/230kV Tiruvallam SS								
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTTP								
	iv. N-1 violation 2x250 MVA ICT at 400/230kV NEYVELI Stage2								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

National Load Despatch Centre, New Delhi
Import Capability of S3 for March 2025

Issue Date: 26/03/2024

Issue Time: 1800 Hrs

Revision No. 0

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	Approved GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st to 31st Mar 2025	00-24	1-96	4350	90	4260	2679	1581		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ICT of (2x315 MVA +1x500 MVA) 400/220kV ICT at Kozhikode SS will lead to over-loading of the Other ICT								
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

