

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for May 2017

Issue Date: 26/05/2017

Issue Time: 1600 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2017 to 20th May 2017	00-24	7200	382	6818	4050	2768		
21st May 2017	00-06	7200		6818		2768		
	06-24	6250		5868		1818		
22nd May 2017	00-19	6250		5868		1818		
	19-24	7200		6818		2768		
23rd May 2017 to 31st May 2017	00-24	7200		6818		2768		
Limiting Constraints (any one or combination thereof)								
i. (n-1) contingency of one circuit of 400 kV Mettur-Karamadai will lead to overloading of the other circuit								
ii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit								
iii. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit								
iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit								
v. Low Voltage in Kerala (S3)								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for May 2017

Issue Date: 26/05/2017

Issue Time: 1600 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2017 to 27th May 2017	00-24	3088	84	3004	2494	510		
28th May 2017	00-09 & 18-24	3088	84	3004	2494	510		
	09-18	2588	84	2504	2494	10	-500	Due to Shutdown of 400kV Udumalpet-Palakkad-1.
29th May 2017 to 31st May 2017	00-24	3088	84	3004	2494	510		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit							
	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for May 2017
Transfer Capability for Import of S3 for May 2017

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-Jan-16	01-05-2017 to 31-05-2017	Revision-0	-
1	20-May-17	21-05-2017 & 22-05-2017	Due to Shutdown of 400kV Tiruvalam SS-Palavadi SS-MTPS ST2 line 1&2	S1-S2nS3
2	26-May-17	28-05-2017	Due to Shutdown of 400kV Udumalpet-Palakkad-1	S3