

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for May 2018

Issue Date: 22/05/2018

Issue Time: 1300 Hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2018 to 31st May 2018	00 - 24	6700	450	6250	4837	1413		
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400kV Kolar-Hosur leads to overloading of the other circuit.							
	ii. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad would lead to overloading of the other circuit							
	iii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for May 2018

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2018 to 22nd May 2018	00-24	2900	80	2820	2568	252		
23rd May 2018 to 26th May 2018	00-08	2900	80	2820	2568	252	-400	Revised due to shutdown of 400kV Trichur-Palakkad Ckt-1 on 23rd & 24th and 400kV Trichur-Palakkad Ckt-2 on 25th & 26th May'18. Limiting Constraint would be (n-1) of 400kV Trichur-Palakkad second ckt would lead to Overloading of Palakkad ICTs.
	08-18	2500		2420		0		
	18-24	2500		2420		0		
27th May 2018 to 31st May 2018	00-24	2900	80	2820	2568	252		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for May 2018
Transfer Capability for Import of S3 for May 2018

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-May-18	01-05-2018 to 31-05-2018	Revision-0	-
1	30-Apr-18	Whole Month	Revised due to change in Network Toplogy and Outage of 400kV Hosur-Somanahalli s/c & 400kV Mettur-Palavadi ckt-1	S1-(S2&S3), S3
2	22-May-18	23rd May 2018 to 26th May 2018	Revised due to shutdown of 400kV Trichur-Palakkad Ckt-1 on 23rd &24th and 400kV Trichur-Palakkad Ckt-2 on 25th &26th May'18.	Import of S3