

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for May 2021**

Issue Date: 26/05/2021

Issue Time: 1600 Hrs

Revision No. 7

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2021 to 8th May 2021	00 - 24	7650	450	7200	3452	3748		
9th May 2021 to 15th May 2021	00 - 24	7650	450	7200	3409	3791		
16th May 2021 to 16th May 2021	00 - 24	7650	450	7200	3486	3714		
17th May 2021 to 21st May 2021	00 - 24	7650	450	7200	3638	3562		
22nd May 2021 to 27th May 2021	00 - 24	7650	450	7200	3602	3598		
28th May 2021	00 - 08	7650	450	7200	3602	3598		
28th May 2021	08 - 24	6850	450	6400	3602	2798	-800	Revision 7 : Due to 800kV Raigarh-Pugulur - 1 & 2 shutdown
29th May 2021 to 31st May 2021	00 - 24	6850	450	6400	3602	2798	-800	
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT ii. N-1 violation of 400/230kV Thiruvallam 2x315 MVA ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**Natioanal Load Despatch Centre, New Delhi**  
**Transfer Capability for Import of S3 for May 2021**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2021 to 8th May 2021	00-24	3300	90	3210	2716	494		
9th May 2021 to 15th May 2021	00-24	3300	90	3210	2723	487		
16th May 2021 to 16th May 2021	00-24	3300	90	3210	2745	465		
17th May 2021 to 21st May 2021	00-24	3300	90	3210	2786	424		
22nd May 2021 to 31st May 2021	00-24	3300	90	3210	2797	413		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**National Load Despatch Centre**  
**Transfer Capability between S1- (S2&S3) for May 2021**  
**Transfer Capability for Import of S3 for May 2021**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-01-2021	01-05-2021 to 31-05-2021	Revision-0	-
1	29-04-21	01-05-2021 to 31-05-2021	1.Commissioning of HVDC Raigarh -Pugalur pole1&2 2.Commissioning of VSC Pugalur-Trissur Pole-2 3.Commissioning of 400kV Trissur-Kozikode D/C 4.Outages approved in 177th SRPC OCC considered	S1-(S2nS3) &S3
2	06-05-21	07-05-21	Revision-2 : Due to Bipole-1 outage of 800kV Raigarh-Pugalur HVDC for testing of Bipole-2	S1-(S2nS3)
3	06-05-21	07-05-21	Revision-3 : TTC/ATC restored back due to deferment of 800kV Raigarh Pugalur Bipole-2 testing	S1-(S2nS3)
4	07-05-21	08-05-2021 to 31-05-2021	1.Commissioning of HVDC Raigarh -Pugalur pole1&2 2.Commissioning of VSC Pugalur-Trissur Pole-2 3.Commissioning of 400kV Trissur-Kozikode D/C 4.Outages approved in 177th SRPC OCC considered	S1-(S2nS3) &S3
5	22-05-21	24-05-2021 to 31-05-2021	Due to 800kV Raigarh-Pugalur 1 & 2 shutdown	S1-(S2nS3) &S3
6	23-05-21	24-05-2021 to 31-05-2021	Restored back TTC/ATC due to postpone of 800kV Raigarh-Pugalur -1 &2 shutdown in view of cyclone alerts to SR states	S1-(S2nS3) &S3
6	26-05-21	28-05-2021 to 31-05-2021	Due to 800kV Raigarh-Pugalur 1 & 2 shutdown	S1-(S2nS3) &S3