

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for May 2022

Issue Date: 29/04/2022

Issue Time: 1800 Hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 9th May 2022	00 - 24	8750	450	8300	4249	4051		
10th May 2022 to 19th May 2022	00 - 24	8750	450	8300	4327	3973		
20th May 2022 to 28th May 2022	00 - 24	8750	450	8300	4091	4209		
29th May 2022 to 31st May 2022	00 - 24	8750	450	8300	4295	4005		
Limiting Constraints (any one or combination thereof)	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	ii. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2							
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

Natioanl Load Despatch Centre, New Delhi
Import Capability of S3 for May2022

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2022 to 9th May 2022	00-24	3300	90	3210	2626	584		
10th May 2022 to 19th May 2022	00-24	3300	90	3210	2647	563		
20th May 2022 to 28th May 2022	00-24	3300	90	3210	2589	621		
29th May 2022 to 31st May 2022	00-24	3300	90	3210	2644	566		
Limiting Constraint (any one or	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
	iii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

