

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for November 2019

Issue Date: 04/11/2019

Issue Time: 1300 Hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st November 2019 to 04th November 2019	00 - 24	6900	490	6410	3451	2959		
05th November 2019	00 - 09	6900		6410		2959		
	09 -24	5400		4910		1459	-1500	Due to shutdown of 400kV Mettur - Karamada - 1.
06th November 2019 to 14th November 2019				6410		2959		
15th November 2019 to 17th November 2019	00 - 24	6900		-490	3273	3137		
18th November 2019 to 24th November 2019				-490	3415	2995		
25th November 2019 to 30th November 2019				-490	3492	2918		
Limiting Constraints (any one or combination thereof)	i. (n-1) of one line of 400kV Mettur – Karamadai D/C will lead to Low Voltage at 400kV Karamadai SS ii. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit iii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability for Import of S3 for November 2019

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st November 2019 to 14th November 2019	00-24	3150	90	3060	2689	371		
15th November 2019 to 17th November 2019					2635	425		
18th November 2019 to 24th November 2019					2674	386		
25th November 2019 to 30th November 2019					2655	405		
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Tirunelveli - Kochi - 1 will lead to under-voltage at 400kV Thrissur S/S							
Note-1	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for November 2019
Transfer Capability for Import of S3 for November 2019

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-07-2019	01-11-2019 to 30-11-2019	Revision-0	-
1	29-10-2019	01-11-2019 to 30-11-2019	Revision - 1 . Due to commissioning of new elements since July and considering Unit Outages as approved in 160th OCCM	
2	04-11-2019	05-11-2019	Due to the Outage of 400kV Mettur - Karamadai - 1 for maintenance works	S1-(S2&S3)