

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for Nov 2023**

Issue Date: 02/11/2023

Issue Time: 1830 Hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) *	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Nov 2023 to 30th Nov 2023	00 - 06 and 18 -24Hrs	10000	450	9550	3587	5963	1450	
	06 - 18 Hrs	10000	450	9550	3537	6013	1450	
Limiting Constraints (any one or combination thereof)	i. Tripping of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur SS							
	ii. N-1 violation 2x315 MVA ICTs at 400/230kV Tiruvallam SS							
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP							
	iv. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**Natioanl Load Despatch Centre, New Delhi**  
**Import Capability of S3 for Nov 2023**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Nov 2023	00-07:30	3950	90	3860	2784	1076		
	07:30-24	3635	90	3545	2784	761		
2nd Nov 2023	00-24	3950	90	3860	2784	1076		
3rd Nov 2023	00-07:30	3950	90	3860	2784	1076		
	07:30-24	3635	90	3545	2784	761		
4th Nov 2023	00-09	3950	90	3860	2784	1076		
	09-24	3450	90	3360	2784	576	-500	Revision-03 : Due to shutdown of 400kV/220kV Khozikode ICT-1
5th Nov 2023 to 30th Nov 2023	00-24	3950	90	3860	2784	1076		
Limiting Constraint (any one or combination thereof)	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT							
	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**National Load Despatch Centre**  
**Transfer Capability between S1- (S2&S3) for Nov 2023**  
**Import Capability of S3 for Nov 2023**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Corridor</b>	<b>Changes in TTC w.r.t. Last Revision (MW)</b>
0	26-07-2023	01-11-2023 to 30-11-2023	Revision-0	-	
1	30-10-2023	01-11-2023 to 30-11-2023	Due to commissioning of 400/230kV Vellalaviduthi S/S and 400/230kV ICT 1 at vellalaviduthi S/S	S1-(S2&S3)	1450
	30-10-2023	01-11-2023	Revision -01 :Due to Shutdown of 400KV/220KV MADAKKATHARA-ICT-1	S3	-315
2	01-11-2023	03-11-2023	Revision-02 :Due to Shutdown of 400KV/220KV MADAKKATHARA-ICT-1	S3	-315
3	11-02-2023	04/11/2023	Revision-03 : Due to shutdown of 400kV/220kV Khozikode ICT-1	S3	-500