

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for November 2024**

Issue Date: 17/11//2024

Issue Time: 11:00 Hrs

Revision No. 4

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA S1- (S2&S3) (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks
1 <sup>st</sup> to 30th Nov 2024	00 -24Hrs	1-96	10900	450	10450	5574	4876	900	
Limiting Constraints (any one or combination thereof)	i. N-1 violation 1x500MVA+2x315 MVA ICTs at 400/230kV Kalivandapattu SS								
	ii. Tripping of 400kV NCTPS-Manali S/C will cause overloading of 400kV Alamaty-Manali S/C								
	iv. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP								
	iv. N-1 violation 2x250 MVA ICT at 400/230kV NEYVELI Stage2								
	v. N-1 violation 2x315 MVA ICT at 400/230kV Salem TN								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

**Natioanl Load Despatch Centre, New Delhi  
Import Capability of S3 for November 2024**

Issue Date: 17/11/2024

Issue Time: 11:00 Hrs

Revision No. 4

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	Approved GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1st to 10th Nov 2024	00-24	1-96	4350	90	4260	2679	1581		
11th Nov 2024	00-08	1-32	4350	90	4260	2679	1581		
	08-24	33-96	3850	90	3760	2679	1081		
12th to 13th Nov 2024	00-24	1-96	4350	90	4260	2679	1581		
14th Nov 2024	00-09	1-36	4350	90	4260	2679	1581		
	09-24	37-96	3850	90	3760	2679	1081		
15th to 18th Nov 2024	00-24	1-96	4350	90	4260	2679	1581		
19th Nov 2024	00-08	1-32	4350	90	4260	2679	1581		
	08-24	33-96	4050	90	3960	2679	1281	-300	Due to shutdown of 400KV/220KV MADAKKATHARA-ICT-3
20th to 30th Nov 2024	00-24	1-96	4350	90	4260	2679	1581		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ICT of (2x315 MVA +1x500 MVA) 400/220kV ICT at Kozhikode SS will lead to over-loading of the Other ICT								
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

**National Load Despatch Centre**  
**Transfer Capability between S1- (S2&S3) for November 2024**  
**Import Capability of S3 for November 2024**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Change in TTC/ATC w.r.t previous revision(MW)</b>	<b>Corridor</b>
0	24-11-2023	01-11-2024 to 30-11-2024	Revision-0		-
1	22-10-2024	01-11-2024 to 30-11-2024	Revision-1		S1-(S2&S3)
			Revision-1		S3 Import
2	09-11-2024	11-11-2024	Revision-02 : Due to shutdown of 400kV/220kV Khozikode ICT-1	-500	S3 Import
3	13-11-2024	14-11-2024	Revision-03 : Due to VSC Pugalur-Thrissur Black start mock drill exercise using 400KV/220KV THRISSUR HVDC-ICT-2	-500	S3 Import
4	17-11-2024	19-11-2024	Revision-04 : Due to shutdown of 400KV/220KV MADAKKATHARA-ICT-3	-300	S3 Import