

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for October 2018**

Issue Date: 12/10/2018

Issue Time: 1115 Hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2018 to 11th October 2018	00 - 24	8047	463	7584	4405	3179		
12th October 2018	00 -11	8047	463	7584	4405	3179	0	
	11 - 24	7250		6787		2382		
13th October 2018 to 26th October 2018	00 -24	7250	463	6787	4405	2382	-797	Due to 400kV Kalivindhapattu - Pugalur D/C SD for LILO works at Ariyalur
27th October 2018 to 31st October 2018	00 - 24	8047		7584		3179		
Limiting Constraints (any one or combination thereof)	i. (n-1) contingency of one circuit of 400 kV Hosur - Salem will lead to overloading of the other circuit							
	ii. (n-1) of 765/400kV ICT at Tiruvalum.							
	iii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit							
	iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit							
	v. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability for Import of S3 for October 2018**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA)</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st October 2018 to 2nd October 2018	00-24	3020	92	2928	2710	218		
3rd October 2018	00-07'	3020	92	2928	2710	218		
	07-24	2520		2428		-282		
4th October 2018 to 9th October 2018	00-07'	3020	92	2928	2710	218		
	07-24	3020		2928		218		
10th October 2018 to 31st October 2018	00-24	3020	92	2928	2710	218		
Limiting Constraint (any one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit *							
	ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and							

**National Load Despatch Centre**  
**Transfer Capability between S1- (S2&S3) for October 2018**  
**Transfer Capability for Import of S3 for October 2018**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>	<b>Corridor</b>
0	26-06-2018	01-10-2018 to 31-10-2018	Revision-0	-
1	02-10-2018	03-10-2018 to 09-10-2018	Revised due to Shutdown of 230kV Tirunelveli-Edamon D/C.	Import of S3
2	03-10-2018	04-10-2018 to 09-10-2018	Revised as the identer is not availing the 230kV Tirunelveli-Edamon D/C Shutdown.	Import of S3
3	12-10-2018	13-10-2018 to 26-10-2018	Due to 400kV Kalivindhapattu - Pugalur D/C SD for LILO works at Ariyalur	S1-(S2&S3)