## Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for September 2017

Issue Date: 26/05/2	Issue Time: 1700 Hrs			Revision No. 0				
Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2017 to 30th September 2017	00 - 24	7410	440	6970	4212	2758		
Limiting Constraints (any one or combination thereof)	<ul> <li>a. (n-1) of 765/400kV ICT at Tiruvalum.</li> <li>b. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit</li> <li>b. (n-1) contingency of one circuit of 400 kV Mettur-Karamadai will lead to overloading of the other circuit</li> <li>b. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit</li> <li>b. (n-1) contingency of one circuit of 400 kV Hosur-Salem will lead to overloading of the other circuit</li> <li>b. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit</li> <li>b. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit</li> <li>b. Low Voltage in Kerala (S3)</li> </ul>							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

## Natioanl Load Despatch Centre, New Delhi Transfer Capability for Import of S3 for September 2017

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2017 to 30th September 2017	00-24	3020	90	2930	2315	615		
Limiting Constraint (any one or	<ul> <li>i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit</li> <li>ii. Low Voltage in Kerala (S3)</li> </ul>							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System							

## National Load Despatch Centre Transfer Capability between S1- (S2&S3) for September 2017 Transfer Capability for Import of S3 for September 2017

Revision No	Date of Revision	Period of Revision	<b>Reason for Revision</b>	Corridor	