

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for September2021

Issue Date: 30/08/2021

Issue Time: 1600 Hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2021 to 2nd September 2021	00 - 24	7250	450	6800	3571	3229		
3rd September 2021 to 8th September 2021	00 - 24	7250	450	6800	3512	3288		
9th September 2021 to 12th September 2021	00 - 24	7250	450	6800	3402	3398		
13th September 2021 to 18th September 2021	00 - 24	7250	450	6800	3462	3338		
19th September 2021 to 22th September 2021	00 - 24	7250	450	6800	3512	3288		
23rd September 2021 to 23rd September 2021	00 - 24	7250	450	6800	3462	3338		
24th September 2021 to 28th September 2021	00 - 24	7250	450	6800	3556	3244		
29th September 2021 to 30th September 2021	00 - 24	7250	450	6800	3699	3101		
Limiting Constraints (any one or combination thereof)	i. N-1 violation 2x315 MVA ICT at 400/230kV Thiruvallam ICT							
	ii. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	iii. N-1 violation 2x250 MVA ICT at 400/230kV Neyveli stage2 ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for September2021

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2021 to 2nd September 2021	00-24	3350	90	3260	2615	645		
3rd September 2021 to 8th September 2021	00-24	3350	90	3260	2652	608		
9th September 2021 to 12th September 2021	00-24	3350	90	3260	2667	593		
13th September 2021 to 18th September 2021	00-24	3350	90	3260	2630	630		
19th September 2021 to 22th September 2021	00-24	3350	90	3260	2599	661		
23rd September 2021 to 23rd September 2021	00-24	3350	90	3260	2630	630		
24th September 2021 to 28th September 2021	00-24	3350	90	3260	2608	652		
29th September 2021 to 30th September 2021	00-24	3350	90	3260	2644	616		
Limiting Constraint (any one or	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for September2021
Transfer Capability between S1- (S2&S3) for September2021

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-05-21	01-09-2021 to 30-09-2021	Revision-0	-
1	30-08-21	01-09-2021 to 30-09-2021	Revision-1 1.September LGBR with updated network 2.ISGS unit outages approved in 181st OCC meeting	S1-(S2nS3) &S3