

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for September2021

Issue Date: 04/09/2021

Issue Time: 1600 Hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2021 to 2nd September 2021	00 - 24	7250	450	6800	3571	3229		
3rd September 2021 to 8th September 2021	00 - 24	7250	450	6800	3512	3288		
9th September 2021 to 12th September 2021	00 - 24	7250	450	6800	3402	3398		
13th September 2021 to 18th September 2021	00 - 24	7250	450	6800	3462	3338		
19th September 2021 to 22th September 2021	00 - 24	7250	450	6800	3512	3288		
23rd September 2021 to 23rd September 2021	00 - 24	7250	450	6800	3462	3338		
24th September 2021 to 28th September 2021	00 - 24	7250	450	6800	3556	3244		
29th September 2021 to 30th September 2021	00 - 24	7250	450	6800	3699	3101		
Limiting Constraints (any one or combination thereof)	i. N-1 violation 2x315 MVA ICT at 400/230kV Thiruvallam ICT							
	ii. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	iii. N-1 violation 2x250 MVA ICT at 400/230kV Neyveli stage2 ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

Natioanl Load Despatch Centre, New Delhi
Import Capability of S3 for September 2021

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2021 to 2nd September 2021	00-24	3350	90	3260	2615	645		
3rd September 2021 to 5th September 2021	00-24	3350	90	3260	2652	608		
6th September 2021	00-08	3350	90	3260	2652	608		
	08-24	3050	90	2960	2652	308	-300	Revision-2 : Due to shutdown of 400kV/220kV Madakkathara ICT-3 shutdown
7th September 2021 to 8th September 2021	00-24	3350	90	3260	2652	608		
9th September 2021 to 12th September 2021	00-24	3350	90	3260	2667	593		
13th September 2021 to 18th September 2021	00-24	3350	90	3260	2630	630		
19th September 2021 to 22th September 2021	00-24	3350	90	3260	2599	661		
23rd September 2021 to 23rd September 2021	00-24	3350	90	3260	2630	630		
24th September 2021 to 28th September 2021	00-24	3350	90	3260	2608	652		
29th September 2021 to 30th September 2021	00-24	3350	90	3260	2644	616		
Limiting Constraint (any one or	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre
Transfer Capability between S1- (S2&S3) for September2021
Import Capability of S3 for September 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-05-2021	01-09-2021 to 30-09-2021	Revision-0	-
1	30-08-2021	01-09-2021 to 30-09-2021	Revision-1 1.September LGBR with updated network 2.ISGS unit outages approved in 181st OCC meeting	S1-(S2nS3) &S3
2	04-09-2021	06-09-2021	Revision-2 : Due to shutdown of 400kV/220kV Madakkathara ICT-3 shutdown	S3