

National Load Despatch Centre
Import of Sikkim Transfer Capability for December 2021

Issue Date: 26th November 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2021 to 31st December 2021	06:00 to 12:00	162.97	1.88	161.09	131.019	30		
1st December 2021 to 31st December 2021	12:00 to 18:00	189	2.6	186.4	131.019	55		
1st December 2021 to 31st December 2021	18:00 to 06:00	171	2.6	168.4	131.019	37		
Limiting Constraints	6 hrs to 12 hrs-132/66.00 KV THERMAL LOADING LIMIT 12 to 18 hrs-.132/66.00 KV THERMAL LOADING LIMIT 18 hrs to 6 hrs-1.66 KV GANGTOK TO LLHP LOADING LIMIT 2.132/66.00 KV THERMAL LOADING LIMIT							