

National Load Despatch Centre
Import of Sikkim Transfer Capability for April 2021

Issue Date: 26th March 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2021 to 30th April 2021	0-18, 22-24	287.3	1.7	285.6	178.24	107		
1st April 2021 to 30th April 2021	18-22	315.56	2.44	313.12	178.24	135		
Limiting Constraints		132 kV Rangit to Sagbari thermal loading exceeded						

National Load Despatch Centre			
Import of Sikkim Transfer Capability for April 2021			
Revision No	Date of	Period of	Reason for Revision