

National Load Despatch Centre
Import of Sikkim Transfer Capability for June 2021

Issue Date: 26th May 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2021 to 31st June 2021	0-18, 22-24	287.3	1.7	285.6	149	137		
1st June 2021 to 31st June 2021	18-22	315.56	2.44	313.12	149	164		
Limiting Constraints		132 kV Rangit to Sagbari thermal loading exceeded						