

**POWER SYSTEM OPERATION CORPORATION LIMITED  
NATIONAL LOAD DESPATCH CENTRE  
NEW DELHI**

**Date of Reporting: 15-Nov-17  
System Reliability Indices Report for: 14-Nov-17**

**Percentage (%) of times ATC was violated**

1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
5	NER Import	0	0.00	0.00

**Percentage(%) of times (N-1) Criteria was violated**

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	0	0.00	0.00
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
4	NER Import	0	0.00	0.00

Remarks: Flows crossing Total Transfer Capability (TTC) on interregional corridors has been worked out as a proxy for (N-1) violation.

### Voltage Profile for the day of 14-Nov-2017

Region	Station	%age of time Voltage below 728/380 kV	%age of time Voltage between 728/380 kV & 800/420 kV	%age of time Voltage above 800/420 kV	Voltage deviation index (%age of time voltage is outside IEGC band)	Maximum Voltage (kV)	Minimum Voltage (kV)	Average Voltage (kV)	
NR	Agra	0.00%	100.00%	0.00%	0.00%	795	766	780	
	Anpara-C	0.00%	100.00%	0.00%	0.00%	775	767	771	
	Anpara-D	0.00%	100.00%	0.00%	0.00%	773	765	770	
	Anta	0.00%	100.00%	0.00%	0.00%	793	773	781	
	Ballia	0.00%	100.00%	0.00%	0.00%	786	767	777	
	Bara	0.00%	100.00%	0.00%	0.00%	759	763	769	
	Bhiwani	0.00%	95.76%	4.24%	4.24%	804	780	792	
	Fatehpur	0.00%	100.00%	0.00%	0.00%	776	750	760	
	Greater Noida	0.00%	94.03%	5.97%	5.97%	806	781	789	
	Jhatikara	0.00%	93.19%	6.81%	6.81%	804	779	792	
	Kanpur GIS	0.00%	100.00%	0.00%	0.00%	751	754	758	
	Lucknow	0.00%	100.00%	0.00%	0.00%	794	772	783	
	Lalitpur	0.00%	100.00%	0.00%	0.00%	786	774	780	
	Meerut	0.00%	90.49%	8.33%	8.33%	811	780	792	
	Moga	0.00%	100.00%	0.00%	0.00%	793	761	781	
	Phagi	0.00%	100.00%	0.00%	0.00%	796	771	782	
Varanasi	0.00%	100.00%	0.00%	0.00%	788	771	779		
Unnao	0.00%	100.00%	0.00%	0.00%	775	752	755		
WR	Akola	0.00%	100.00%	0.00%	0.00%	787	756	773	
	Aurangabad	0.00%	100.00%	0.00%	0.00%	796	758	781	
	Bhopal (BDTCL)	0.00%	100.00%	0.00%	0.00%	791	749	770	
	Bilaspur	0.00%	100.00%	0.00%	0.00%	772	757	765	
	Bina	0.00%	100.00%	0.00%	0.00%	788	759	773	
	Champa	0.00%	93.75%	3.13%	3.13%	804	787	795	
	Dharamjaigarh	0.00%	100.00%	0.00%	0.00%	782	768	774	
	Dhule (BDTCL)	0.00%	100.00%	0.00%	0.00%	799	757	781	
	Gwalior	0.00%	100.00%	0.00%	0.00%	792	764	778	
	Indore	0.00%	100.00%	0.00%	0.00%	794	746	772	
	Jabalpur	0.00%	100.00%	0.00%	0.00%	794	766	778	
	Koradi	0.00%	100.00%	0.00%	0.00%	777	754	767	
	Pune	0.00%	100.00%	0.00%	0.00%	789	744	770	
	Raigarh Pooling	0.00%	93.06%	6.94%	6.94%	804	788	796	
	Raipur Pooling	0.00%	100.00%	0.00%	0.00%	797	778	789	
	Sasan	0.00%	100.00%	0.00%	0.00%	770	756	763	
	Seoni	0.00%	100.00%	0.00%	0.00%	788	759	775	
	Sipat	0.00%	100.00%	0.00%	0.00%	770	758	764	
	Solapur	0.00%	97.92%	2.08%	2.08%	802	769	789	
	Tamnar	0.00%	86.39%	13.61%	13.61%	805	790	798	
	Tirora	0.00%	100.00%	0.00%	0.00%	771	754	764	
	Vadodara	0.00%	100.00%	0.00%	0.00%	792	760	779	
	Kurnool	0.00%	100.00%	0.00%	0.00%	800	775	787	
	Nellore PS	0.00%	100.00%	0.00%	0.00%	797	777	786	
Raichur	0.00%	100.00%	0.00%	0.00%	800	777	788		
SR	Nizamabad	0.00%	100.00%	0.00%	0.00%	798	770	785	
	Srikakulam	0.00%	99.58%	0.42%	0.42%	801	782	793	
	Thiruvallam	0.00%	58.26%	41.74%	41.74%	814	792	801	
	Vemagiri	0.00%	100.00%	0.00%	0.00%	798	775	786	
	Angul	0.00%	100.00%	0.00%	0.00%	794	779	787	
	ER	Gaya	0.00%	100.00%	0.00%	0.00%	784	767	776
		Jharsuguda	0.00%	100.00%	0.00%	0.00%	796	783	788
Ranchi		0.00%	100.00%	0.00%	0.00%	795	781	788	
Sasaram		0.00%	100.00%	0.00%	0.00%	780	730	752	
NER	Azara (400 kV)	0.00%	100.00%	0.00%	0.00%	412	405	409	
	Bongaigaon (400 kV)	0.00%	100.00%	0.00%	0.00%	413	399	408	
	Bongaigaon TPS (400 kV)	0.00%	88.19%	11.81%	11.81%	421	407	417	
	Byrnhat (400 kV)	0.00%	100.00%	0.00%	0.00%	412	405	409	
	Palatana (400 kV)	0.00%	90.69%	5.76%	5.76%	421	415	405	
	Misa (400 kV)	0.00%	95.42%	4.58%	4.58%	423	404	414	
	Biswanath Chariali (400 kV)	0.00%	99.38%	0.07%	0.07%	421	398	411	
Silchar (400 kV)	0.00%	100.00%	0.00%	0.00%	418	405	413		

Remarks: Unless otherwise specified, station may be treated as 765kV S/S.