

**POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE
NEW DELHI**

System Reliability Indices Report for the month of April 2016

Date: 23-May-2016

Percentage (%) of times ATC was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	78	19.50	2.71
2	ER-NR	0	0.00	0.00
3	Import of NR	364	91.00	12.64
4	NEW-SR	370	92.50	12.85
5	ER-NER	0	0.00	0.00

Percentage(%) of times (N-1) Criteria was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	13	3.25	0.45
2	ER-NR	0	0.00	0.00
3	Import of NR	37	9.25	1.28
4	NEW-SR	17	4.25	0.59
4	ER-NER	0	0.00	0.00

Remarks: Flows crossing Total Transfer Capability (TTC) on interregional corridors has been worked out as a proxy for (N-1) violation.