

**POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE
NEW DELHI**

System Reliability Indices Report for the month of May 2016

Date: 23-Jun-2016

Percentage (%) of times ATC was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	130	32.50	4.37
2	ER-NR	96	24.00	3.23
3	Import of NR	1023	255.75	34.38
4	NEW-SR	167	41.75	5.61
5	ER-NER	0	0.00	0.00

Percentage(%) of times (N-1) Criteria was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	12	3.00	0.40
2	ER-NR	90	22.50	3.02
3	Import of NR	292	73.00	9.81
4	NEW-SR	0	0.00	0.00
4	ER-NER	0	0.00	0.00

Remarks: Flows crossing Total Transfer Capability (TTC) on interregional corridors has been worked out as a proxy for (N-1) violation.