

GRID CONTROLLER OF INDIA LIMITED
(Formerly known as POWER SYSTEM OPERATION CORPORATION LIMITED)
NATIONAL LOAD DESPATCH CENTRE
NEW DELHI

System Reliability Indices Report for the week from
10-Jun-2024 to 16-Jun-2024

Date: 21-Jun-2024

Percentage (%) of times ATC was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	77	19.25	11.46
2	ER-NR	0	0.00	0.00
3	Import of NR	19	4.75	2.83
4	NEW-SR	0	0.00	0.00
5	ER-NER	0	0.00	0.00

Percentage(%) of times (N-1) Criteria was violated

S.No.	Corridor	Number of Blocks Violated	Number of Hours Violated	%Violation
1	WR-NR	16	4.00	2.38
2	ER-NR	0	0.00	0.00
3	Import of NR	0	0.00	0.00
4	NEW-SR	0	0.00	0.00
4	ER-NER	6	1.50	0.89

Remarks: Flows crossing Total Transfer Capability (TTC) on interregional corridors has been worked out as a proxy for (N-1) violation.

