

National Load Despatch Centre
Import of Tripura Transfer Capability for November 2021

Issue Date: 27th Oct 2021

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Nov 2021 to 30th Nov 2021	00 - 17	365	6	359	0	359	-	
	17 - 21	310	6	304	0	304	-	
	21 - 24	365	6	359	0	359	-	
Limiting Constraints		N-1 of 132 kV SM-Nagar (TR) -SM Nagar(ISTS) S/C and limiting element observed is 132 kV PK-Bari (TR)- PK Bari (ISTS) S/C						