Natioanl Load Despatch Centre, New Delhi Transfer Capability between India and Bangladesh for April 2017

Issue Date: 28/12/2016		Issue Time: 1745 hrs			Revision No. 0				
Date	Time Period in IST (hrs)	TTC from India to Bangladesh from Indian Side*	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
1st April 17 to 30th April 17	0000-0630	500	0	500	290	210		No constraints	
	0630-2330	500		500	290	210		from Indian	
	2330-2400	500		500	290	210		Side.	

Note 1:	There is no limitation on the flow on HVDC Bheramera from the Indian side during normal conditions.			
Note 2:	In case of operation of SPS, Transfer Capability will be revised accordingly.			
Note 3:	Schedule between India and Bangladesh will be prepared using the above table till the next revision			
Note 4:	Transfer Capabiliy between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.			

National Load Transfer Capability between Inc

Revision	Date of	Period of		
No	Revision	Revision		

Despatch Centre dia and Bangladesh for April 2017

Reason for Revision