## Natioanl Load Despatch Centre, New Delhi Transfer Capability between India and Bangladesh for August 2016

Date	Time Period in IST (hrs)	TTC from India to Bangladesh from Indian Side*	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	for Short Term	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
1st August 16 to	0000-0630	500		500	460	40		No constraints	
31st August 16	0630-2330	500	0	500	460	40		from Indian	
	2330-2400	500		500	460	40		Side.	

Note 1:	There is no limitation on the flow on HVDC Bheramera from the Indian side during normal conditions.				
Note 2:	In case of operation of SPS, Transfer Capability will be revised accordingly.				
Note 3:	Schedule between India and Bangladesh will be prepared using the above table till the next revision				
Note 4:	Transfer Capabiliy between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.				

## National Load Despatch Centre Total Transfer Capability for August 2016

Revision	Date of	Period of	Reason for Revision		
No	Revision	Revision			