

Natioanl Load Despatch Centre
Transfer Capability between India and Bangladesh for December 2014

Issue Date: 30/11/2014

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2014 to 31st December 2014	0000-1030	250	0	250	460	0		
	1030 - 1630	250		250	460	0		
	1630-2130	500		500	460	40		
	2130-2400	250		250	460	0		

1st Dec'14 to 31st Dec'14	
Time Period	Limiting Constraints
0000-1700	
1700-2200	
2200-2400	

Note: In case of operation of SPS, Transfer Capability will be revised accordingly.

NLDC Bangladesh has vide Memo no LDC/PGCB/35/2014/463 and earlier email on 7th Nov 2014 has advised the following limits of power flow through HVDC Bheramara

S. No.	BST	IST	Quantum of Power (MW)
1	00:00 to 17:00	23:30 to 16:30	250
2	17:00 to 22:00	16:30 to 21:30	500
3	22:00 to 24:00	21:30 to 23:30	250