

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between India and Bangladesh for December 2016

Issue Date: 08/12/2016

Issue Time: 1300 hrs

Revision No. 1

Date	Time Period in IST (hrs)	TTC from India to Bangladesh from Indian Side*	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
1st December 16 to 08th December 16	0000-0630	500	0	500	210	290		No constraints from Indian Side.	
	0630-2330	500		500	210	290			
	2330-2400	500		500	210	290			
9th December 16	0000-0630	500	0	500	210	290	-500	No constraints from Indian Side.	
	0630-1530	0		0	210	0			
	1530-2330	0		0	210	0			
	2330-2400	0		0	210	0			
10th December 16	0000-0630	0	0	0	210	0	-500	No constraints from Indian Side.	Revised due to shutdown of HVDC Bheramera B/B
	0630-1530	0		0	210	0			
	1530-2330	0		0	210	0			
	2330-2400	0		0	210	0			
11th December 16	0000-0630	0	0	0	210	0	-500	No constraints from Indian Side.	
	0630-1530	0		0	210	0			
	1530-2330	500		500	210	290			
	2330-2400	500		500	210	290			
12th December 16 to 31st December 16	0000-0630	500	0	500	210	290		No constraints from Indian Side.	
	0630-2330	500		500	210	290			
	2330-2400	500		500	210	290			

Note 1:	There is no limitation on the flow on HVDC Bheramera from the Indian side during normal conditions.
Note 2:	In case of operation of SPS, Transfer Capability will be revised accordingly.
Note 3:	Schedule between India and Bangladesh will be prepared using the above table till the next revision
Note 4:	Transfer Capabiliy between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.

National Load Despatch Centre
Transfer Capability between India and Bangladesh for December 2016

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	08-Dec-16	09/12/2016 to 11/12/2016	Revised due to shutdown of HVDC Bheramera B/B