

Natioanl Load Despatch Centre
Transfer Capability between India and Bangladesh for January 2015

Issue Date: 1/1/2015

Issue Time: 1310 hrs

Revision No. 0

Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2015 to 31st January 2015	0000-0630	180	0	180	460	0		
	0630-1630	360		360	460	0		
	1630 - 2130	500		500	460	40		
	2130-2330	250		250	460	0		
	2330-2400	180		180	460	0		

1st Jan'15 to 31st Jan'15	
Time Period	Limiting Constraints
0000-1700	No limiting constraints from Indian side
1700-2200	
2200-2400	
Note 1:	There is no limitation on the flow on HVDC Bheramera from the Indian side during normal conditions.
Note 2:	In case of operation of SPS, Transfer Capability will be revised accordingly.

NLDC Bangladesh has vide Memo no LDC/PGCB/35/2014/522 and earlier email on 18th December 2014 has advised the following limits of power flow through HVDC Bheramara

S. No.	BST	IST	Quantum of Power (MW)
1	00:00 to 07:00	23:30 to 06:30	180
2	07:00 to 17:00	06:30 to 16:30	360
3	17:00 to 22:00	16:30 to 21:30	500
4	22:00 to 24:00	21:30 to 23:30	250

**National Load Despatch Centre
Total Transfer Capability for January 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision