## Natioanl Load Despatch Centre, New Delhi Transfer Capability between India and Bangladesh for January 2017

Issue Date: 28/9/2016			Issue Tir	ne: 1615 hr	S	Revision No. 0				
	Date	Time Period in IST (hrs)	TTC from India to Bangladesh from Indian Side*	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
	1st January 17 to 31st January 17	0000-0630	500	0	500	210	290		No constraints	
		0630-2330	500		500	210	290		from Indian	
		2330-2400	500		500	210	290		Side.	

Note 1:	There is no limitation on the flow on HVDC Bheramera from the Indian side during normal conditions.
Note 2:	In case of operation of SPS, Transfer Capability will be revised accordingly.
Note 3:	Schedule between India and Bangladesh will be prepared using the above table till the next revision
Note 4:	Transfer Capabiliy between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.

## National Load Despatch Centre Transfer Capability between India and Bangladesh for January 2017

Revision	Date of	Period of	<b>Reason for Revision</b>	
No	Revision	Revision		