

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between India and Bangladesh for June 2017

Issue Date: 27/2/2017

Issue Time: 1745 hrs

Revision No. 0

Date	Time Period in IST (hrs)	TTC from India to Bangladesh from Indian Side*	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
1st June 17 to 30th June 17	0000-0630	500	0	500	290	210		No constraints from Indian Side.	
	0630-2330	500		500	290	210			
	2330-2400	500		500	290	210			

Note 1:	There is no limitation on the flow on HVDC Bheramera from the Indian side during normal conditions.
Note 2:	In case of operation of SPS, Transfer Capability will be revised accordingly.
Note 3:	Schedule between India and Bangladesh will be prepared using the above table till the next revision
Note 4:	Transfer Capabily between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.

National Load Despatch Centre
Transfer Capability between India and Bangladesh for June 2017

Revision No	Date of Revision	Period of Revision	Reason for Revision