Natioanl Load Despatch Centre, New Delhi Transfer Capability between India and Bangladesh for November 2015

Date	Time Period in IST (hrs)	TTC from India to Bangladesh from Indian Side*	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	for Short Term	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
1st Nov 2015 to 30th Nov 2015	0000-0630	500	0	500	460	40		No constraints	
	0630-2330	500		500	460	40		from Indian	
	2330-2400	500		500	460	40		Side.	

Note 1:	There is no limitation on the flow on HVDC Bheramera from the Indian side during normal conditions.				
Note 2:	In case of operation of SPS, Transfer Capability will be revised accordingly.				
Note 3:	Schedule between India and Bangladesh will be prepared using the above table till the next revision				
Note 4:	4: Transfer Capabiliy between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.				

National Load Despatch Centre Total Transfer Capability for November 2015

Revision	Date of	Period of	Reason for Revision		
No	Revision	Revision			