

**National Load Despatch Centre, New Delhi**  
**Transfer Capability between India and Bangladesh for October 2019**

Issue Date: 28th June 2019

Issue Time: 1800 hrs

Revision No. 0

Date	Time Period in IST (hrs)	TTC from India to Bangladesh from Indian Side*	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
1st October 19 to 31st October 19	0000-0630	1000	0	1000	510	490		Under N-1 of 400 kV Berhampore Bheramara, voltage at Berhampore tends to dip.	
	0630-2330	1000		1000	510	490			
	2330-2400	1000		1000	510	490			

Note 1:	In case of operation of SPS, Transfer Capability will be revised accordingly.
Note 2:	Schedule between India and Bangladesh will be prepared using the above table till the next revision
Note 3:	Transfer Capability between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.
Note 4:	LTA of Bangladesh is considered as 300 MW from DVC and 210 MW from ISGS allocation (excluding auxiliaries+losses)

**National Load Despatch Centre**  
**Transfer Capability between India and Bangladesh for October 2019**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>