

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between India and Bangladesh for September 2016**

Issue Date: 08/7/2016

Issue Time: 1700 hrs

Revision No. 1

Date	Time Period in IST (hrs)	TTC from India to Bangladesh from Indian Side*	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Limiting constraint	Comments
1st September 16 to 30th September 16	0000-0630	500	0	500	210	290		No constraints from Indian Side.	STOA margin revised due to completion of MTOA from WBSEDCL to Bangladesh.
	0630-2330	500		500	210	290			
	2330-2400	500		500	210	290			

Note 1:	There is no limitation on the flow on HVDC Bheramera from the Indian side during normal conditions.
Note 2:	In case of operation of SPS, Transfer Capability will be revised accordingly.
Note 3:	Schedule between India and Bangladesh will be prepared using the above table till the next revision
Note 4:	Transfer Capabiliy between India and Bangladesh in the above table has been evaluated ignoring the constraints from Bangladesh side.

**National Load Despatch Centre  
Total Transfer Capability for September 2016**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	08-Jul-16	Whole Month	STOA margin revised due to completion of MTOA from WBSEDCL to Bangladesh.