

Natioanal Load Despatch Centre
Transfer Capability between India and Bangladesh for September 2014

Issue Date: 31/08/2014

Issue Time: 2030 hrs

Revision No. 0

Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2014 to 6th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		
7th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2400	450		450	330	120		
8th September 2014 to 13th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		
14th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2400	450		450	330	120		
15th September 2014 to 20th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		
21st September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2400	450		450	330	120		
22nd September 2014 to 27th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		
28th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	500		500	330	170		
	1730 -2400	450		450	330	120		
29th September 2014 to 30th September 2014	0000-1030	500	0	500	330	170		
	1030 - 1730	475		475	330	145		
	1730 -2400	425		425	330	95		

Monday to Saturday

Time Period	Limiting Constraints
0000-1030	---
1030-1730	High loading of 400 kV Farakkka -Behrampur S/C and low voltage at Jeerat
1730-2400	

Sundays

Time Period	Limiting Constraints
0000-1030	---
1030-1730	High loading of 400 kV Farakkka -Behrampur S/C and low voltage at Jeerat
1730-2400	

**National Load Despatch Centre
Total Transfer Capability for September 2014**

Revision No	Date of Revision	Period of Revision	Reason for Revision