

**National Load Despatch Centre**  
**Import of Uttar Pradesh Transfer Capability for August 2021**

Issue Date: 26-07-2021

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2021 to 31st August 2021	00-24	13800	600	13200	7200	6000		<a href="https://www.upslcdc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde">https://www.upslcdc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Sohawal (PG), Gorakhpur (UP), Sarnath, Obra and Agra(PG) ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages