

National Load Despatch Centre
Import of Uttar Pradesh Transfer Capability for July 2021

Issue Date:

Issue Time:

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2021 to 31st July 2021	00-24	13800	600	13200	7200	6000		
Limiting Constraints		N-1 contingency of 400/220kV Sohawal (PG), Gorakhpur (UP), Sarnath and Agra(PG) ICTs, 400/132kV Mau ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages