

**National Load Despatch Centre**  
**Import of Uttar Pradesh Transfer Capability for September 2021**

Issue Date: 28-08-2021

Issue Time: 1600

Revision No. 0

| Date                                      | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW)  | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW) | Margin Available for Short Term Open Access (STOA) (MW) | Changes in TTC w.r.t. Last Revision | Comments  |
|---|--------------------------|---|-------------------------|--|---|---|-------------------------------------|---|
| 1st September 2021 to 30th September 2021 | 00-24                    | 13800   | 600                     | 13200                                    | 7200  | 6000  |                                     | <a href="https://www.upslcdc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde">https://www.upslcdc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde</a> |
| <b>Limiting Constraints</b>               |                          | N-1 contingency of 400/220kV Sohawal (PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs |                         |  |   |   |                                     |   |

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages