

**National Load Despatch Centre  
Urgent Market Information**

Issue Date: 12/05/2 Issue Time: 2015 hrs

TTC/ ATC on ER-NER link has been revised due to revival of 400 kV Binaguri-Bongaigaon II.

Corridor	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER-NER	00-24	400	35	365	200	165	
NER-ER	00-24	400	50	350	0	350	

220 kV Agia-Sarusajai D/C, which is under shutdown, is likely to be revised on 13/ 05/ 2012. TTC between ER-NER would be reviewed once the same is restored.